

STATE OF MICHIGAN
COUNTY OF HURON
VILLAGE OF PORT AUSTIN

ORDINANCE NO. 114-06

ORDINANCE TO AMEND SECTION 12.2.6 AND 12.4.1 OF ORDINANCE 91-04,
GOVERNING THE WATER SUPPLY SYSTEM OF THE VILLAGE OF PORT AUSTIN
AND REGULATING THE USE AND CONSUMPTION OF WATER THEREFROM.

THE VILLAGE OF PORT AUSTIN ORDAINS:

Section 12.2.6 and 12.4.1 of Ordinance No. 91-04 is hereby amended so that after amendment, it shall read in its entirety as follows:

12.2.6 Service Line Size

Pipe from main to the curb stop and from the curb stop to the structure shall be a minimum grade Type K soft temper copper not less than ¾" in diameter or SDR 9 HDPE (rated 200 psi) plastic not less than ¾" in diameter. If SDR 9 HDPE plastic is used, only authority approved materials may be used for the connection. HOSE BARBS ARE PROHIBITED.

12.4.1

The connection of the Type K copper service pipe or the SDR 9 HDPE (rated 200 psi) plastic service pipe to the corporation stop shall be made by using an approved adapter fitting. When plastic pipe is used, it must be accompanied by either a tracer wire or magnetic tape for locating purposes.

The ordinance shall take effect twenty (20) days from or after its adoption.

At a regular meeting of the Port Austin Village Council held at the Port Austin Village Hall on the 26th day of June 2006.

Motion by: William Hogan

Seconded by: Chuck Ruth

Yeas: 7

Nays: 0

Absent: 0

Abstain: 0

President: Tony Loewe

Clerk: Judy Binkley